



# CHARLESTON FIRE DEPARTMENT



## Fire Marshal Division

### Information Bulletin

#### Self Survey Fire Inspection – Places of Worship

Dear Community Partner,

The Charleston Fire Department Fire Marshal Division conducts routine safety surveys in buildings throughout the City each year. These surveys help reduce fires by eliminating basic fire hazards, educating members of the community on potential hazards, and helping to ensure a safe and livable community.

On the backside of this document you will find a courtesy copy of a self-survey checklist to assist you in assessing general safety within your building. Please take a few moments to conduct the survey and begin removing hazards as needed. You may find it useful to conduct monthly, quarterly, or even bi-annual safety surveys based on your facility needs. This form is provided as a voluntary compliance tool to assist you in maintaining a fire safe building.

We encourage all facilities to implement emergency and safety programs to improve safety. We recommend a safety plan that would incorporate the following:

- Emergency plan: A specific response plan that will offer guidance to representatives on how to respond to emergencies such as building evacuation, fire procedures, response to alarms, severe weather, bomb threats, etc. These plans are required for some buildings but recommended for everyone.
- Training: Continual review, training, & updates for your team is a critical component to each plan.

Numerous internet resources are available to assist you in planning and preparations such as:

- CFD Fire Marshal Division emergency plan templated: <https://www.charleston-sc.gov/1016/Fire-and-Emergency-Action-Planning>
- NFPA (National Fire Protection Association) publishes “NFPA 1600: Standard for Disaster/Emergency Management and Business Continuity Programs”. [www.NFPA.org](http://www.NFPA.org).
- OSHA emergency plan system: [www.osha.gov/SLTC/etools/evacuation/expertsystem/default.htm](http://www.osha.gov/SLTC/etools/evacuation/expertsystem/default.htm)
- FEMA emergency planning tips: [www.fema.gov/business/index.shtm](http://www.fema.gov/business/index.shtm)

The Charleston Fire Department is ready to assist you with preventing and responding to emergencies associated with your place of worship. Feel free to contact me at 843-724-3429 or via e-mail at [julazadehm@charleston-sc.gov](mailto:julazadehm@charleston-sc.gov) with any additional questions or comments.

Sincerely,

  
electronic signature

Mike Julazadeh  
Chief Fire Marshal  
Charleston Fire Department

Charleston Fire Department

<b>Places of Worship Fire Safety Self-Survey</b>	Place of Worship: _____	Address: _____	Staff member completing survey: _____	Date: _____
--	-------------------------	----------------	---------------------------------------	-------------

The Charleston Fire Department Fire Marshal Division provides this document as a courtesy to assist you with identifying routine fire safety issues within places of worship. These surveys improve safety by eliminating basic fire hazards, educating staff on potential hazards, and help to ensure a safe and livable community. This form is intended to assist you with general compliance items in your building - the list may not be all inclusive as requirements change based on use and size. The list below is intended to act as a guide to help you begin promoting fire safety within your facilities.

<b>A. MEANS OF EGRESS</b>		N/A	YES	NO
1	Exit doors are easily accessible and unobstructed. The door opens easily and to the full open position.			
2	Exit doors unlatch with a single operation so that anyone in the building can exit without delay.			
3	Fire doors are maintained in the closed position or are self-closing. Fire doors are unobstructed and will fully close.			
4	Exit walkways are clear of storage or items that restrict exit width. A walkway at least 44" wide is provided.			
5	Stairwells (stairs, landing, areas under landing) are clear of storage. Continuous lighting provided in stairwell.			
6	The emergency exit path is marked by exit signs so it is easily identifiable to staff and congregation.			
7	Exit signs and emergency lights are unobstructed and operable under normal and emergency power.			
<b>B. FIRE PROTECTION</b>				
1	Fire extinguishers: Size 2A10BC min., service tag or new tag within 1 year, mounted to wall <5' high, accessible			
2	Are fire extinguishers places so that the maximum travel distance does not exceed 75'?			
3	Fire sprinkler and/or standpipes have been serviced by a licensed fire protection contractor within the last year.			
4	Fire sprinkler valves are clearly labeled (indicating the area served) and locked open or monitored by the fire alarm.			
5	The fire department connection feeding the fire sprinkler or standpipe is easily accessible and labeled.			
6	Storage, displays, etc. is 18" below fire sprinklers, 2' below ceiling in non-sprinkled areas, not higher than 12'.			
7	Standpipe connections are accessible, protective caps are in place and are only hand-tight.			
8	Kitchen hood or specialize extinguishing systems have been serviced within the last 6 months.			
9	Kitchen hood or other hood exhaust systems are maintained clean and are operating (running).			
10	Fire alarm system has been serviced by a licensed fire alarm contractor within the last year.			
11	Fire alarm devices such as pull stations, audio or visual alarms, or other devices are unobstructed and visible.			
<b>C. HEATING SYSTEM</b>				
1	Fuel burning appliances that are vented to the outside have the vent in place which is free of breaks or holes.			
2	Appliance and/or equipment covers are in place and secured to the appliance or equipment.			
3	Spacing of not less than 36" is maintained between combustibles (anything that will burn) and heating systems.			
<b>D. ELECTRICAL</b>				
1	Extension cords are only used on a temporary basis, only for portable items, never in place of permanent wiring.			
2	Breaker box does not have any open slots or circuits, circuits are clearly labeled, breaker cover(s) remain closed.			
3	All electrical junction box covers, outlet covers, and switch plates are secured in place.			
4	Clearance is maintained around the electrical panel at all times (minimum: 30" wide x 36" deep x 78" high)			
<b>E. GENERAL</b>				
1	Prepare Fire Safety & Fire Evacuation plans.			
2	Review and make available for review Fire Safety & Fire Evacuation plans with staff, students, and congregants.			
3	Staff has been trained on the facility emergency plan and training has been documented.			
4	Storage and supplies, etc. are maintained in an orderly manner and not excessive to present a fire or safety hazard.			
5	The property street address & suite identification are posted in not less than 4" tall numbers and/or letters.			
6	If the property has a knox box for fire department entry: has the fire department been notified of any key changes?			
<b>F. REPORTS</b>				
Inspection reports for the following systems should be maintained on site and available for review: Fire Sprinkler Systems, Standpipe Systems, Fire Pumps, Fire Alarms, Hood Suppression, Other Suppression, and Emergency Power Systems.				
<b>OTHER</b>				
<input type="checkbox"/> Staff should routinely survey all exit routes to ensure the exits and exit routes are unobstructed, the walking path does not present any hazards such as trip or fall hazards, and any needed stairs, guardrails, or handrails are in good repair.				